

PRODUCER STATEMENT (PLUMBING TESTING ONLY)

To: Invercargill City Council

Issued by (craftsman plumber): _____

Building Consent Number: _____

At (project address): _____

In relation to (description of building work): i.e. alteration / extension / bathroom / etc.

I have been engaged to undertake the plumbing work on the above building consent. I hereby certify that the work complies with the building consent and that I have undertaken a pressure test for water tightness in accordance with:

- NZ Building Code G12/AS1 – 1500 kPa for a period of not less than 15 minutes
 AS/NZS 3500.1:2003 – 1500 kPa for a period of not less than 30 minutes.
(Tick appropriate box)

and certify that this pressure test passed the indicated method of compliance.

This statement will be accepted and relied on by the Invercargill City Council for testing only of small bathroom / kitchen, laundry alteration up to maximum of 20m of pipework in length.

Registration number (I hereby certify that my registration is current): _____

Name print: _____

Signature: _____ Date: _____

This form is to be handed to the inspector at time of inspection.

Office Use Only

- Form filled out correctly Yes – put this form on building consent file.
 No – If no, pipework is to be tested and viewed by Council inspector. This form to building consent file.
 Failed notice left on site. Preline not approved. Linings not to be installed – reinspection required.